## CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

## LISTING SERVICE

**LISTING No.** 7165-1574:160 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield, NJ, 07004-1561

Contact: Ron Dalton (310) 725-2972 FAX (310) 725-2942

**DESIGN:** Model **Unimode-5** control unit. Local and central station, noncoded, automatic, manual,

waterflow and sprinkler supervisory service. Refer to listee's data sheet for detailed product

description and operational considerations. System components:

Unimode-5 Control Unit
RM-5F Relay Module
ADM-24 Annunciator Driver
XRM-24 Transformer
PRT-24 Printer

CAC-5F Initiating Converter

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and

indicating devices. This control unit can generate the temporal code pattern fire alarm signal as required per NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for

details.

**NOTE:** 1. For Alarm Verification Feature, the maximum retard/reset/restart must be adjusted to 30

sec. or less.

2. Formerly 7165-0085:174

**XLF:** 7165-0075:169

05-20-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 23, 2004 Listing Expires June 30, 2005

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager